



**PUBLIC HEALTH ENGINEERING DEPARTMENT
WATER TESTING LABORATORY, FARIDABAD**
E-mail:-chemist.faridabad@phedharyana.gov.in, chemist.fbd@gmail.com



Test Report No.:-PHL- 115/04/2021	Memo No.:-> 170	Date:- 20/04/2021
Issued to - Ideal Public School ,Lakkarpur Faridabad	Location - 7, I-Block ,Shiv Durga Vihar	
Sample Type : -> Bacteriological Test	Sample collected Date & Time :-> 16 /04/2021 & 11:00 AM	
	Sample received Date & Time :-> 16/04/2021 & 2 :00 PM	

No. of colliforms per 100ml of water	Opinion
0	Water sample is free from bacteriological contamination

Specific contractual notes: -

- ◆ The results given above are related to the sample as received and tested in PHED Lab FARIDABAD.
- ◆ The test report can't be regenerated/ re-produced in whole or part thereof without written permission of PHED Lab FARIDABAD.
- ◆ The test report can't be used for any publicity or any legal purpose.
Reliability of water sample lies with sender/collector of water sample

IDEAL PUBLIC SCHOOL

Darsh
MANAGER

Papri
Principal

IDEAL PUBLIC SCHOOL
I-Block, S.D.V. Lakharpur
Faridabad (Hr.)
CHEMIST

Public Health Engineering Department
Water Testing Lab, Faridabad
CHEMIST

sample analyzed by

For Badami Education Society

U m m
Chairman

PUBLIC HEALTH ENGINEERING DEPARTMENT
WATER TESTING LABORATORY
FARIDABAD

Os



Test Report

Test Report No. – 169	Issue Date :- 20/04/2021
Issue To – Ideal Public School ,Lakkarpur Faridabad	Location – 7, I-Block ,Shiv Durga Vihar
Your Reference No-	Collected By - - Ideal Public School ,Lakkarpur Faridabad
Sample Type – Physical & Chemical	Sample Collected Date & Time:→ 16/04/2021 & 11:00 AM
Name of JE –	Sample Received Date & Time:- 16/04/2021 & 02:00 PM
Lab Job Order No.- PC- 21/04/2021	Sample Quantity :- 1000 ml
Date of Start of Analysis of Sample :- 16/04/2021	Date of End of Analysis of Sample :- 20/04/2021

Results

S. No.	Parameter	Protocol Used	Results	IS:10500:2012 (Second Revision)		Unit
				Desirable limit	Max. Permissible limit (in absence better alternate source)	
1	Total Dissolved	APHA2540 C :2017	60	500	2000	mg/L
2	Total Hardness	APHA2340 C :2017	50	200	600	mg/L
3	Calcium (as Ca)	APHA3500-Ca B:2017	8	75	200	mg/L
4	Magnesium (as Mg)	APHA3500 -Mg B:2017	7.29	30	100	mg/L
5	Total Alkalinity	APHA 2320 B: 2017	80	200	600	mg/L
6	Chloride (as Cl)	APHA4500 -Cl ⁻ B:2017	24.9	250	1000	mg/L
7	Sulphate	APHA 4500-SO ₄ ²⁻ E USEPA 9038	15	200	400	mg/L
8	Fluoride (as F)	APHA 4500-F D, C:2017	0.42	1.0	1.5	mg/L
9	Iron	APHA 3500-Fe B USEPA ,45	0.02	1.0	No relaxation	mg/L
10	Nitrate (as NO ₃)	APHA4500 -NO ₃ ⁻ D :2017	1.5	45	No relaxation	mg/L
11	pH	APHA4500 -H ⁺ B :2017	7.32	6.5 -8.5	No relaxation	pH

Notes:

- The results given above are related to the sample as received and tested in PHED Lab, Faridabad Reliability of sample lies with the sender.
- The test report can't be regenerated/re-produced in whole or in part without written permission of Laboratory.
- The test report can't be used for any publicity or any legal purpose.
- The test samples meant for chemical analysis will be disposed off after 15 days from the date of issue of test
- Report unless until specifically requested by the customer for retaining over a longer period.

Sample analyzed by

IDEAL PUBLIC SCHOOL

 MANAGER

Principal
 IDEAL PUBLIC SCHOOL
 Public Health Engineering Department
 I-Block, S.D. Faridabad
 Water Testing Laboratory
 (Vandana Choudhary)
 Authorized Signatory/Chemist
 PHED Water Testing Laboratory, Faridabad

For Badami Education Society
 Chairman

Health Department, Haryana (Faridabad)
O/o Civil Surgeon, Faridabad

Hygiene Certificate

No. HHC/2021/PHD/000031

Date ... 01.07.2021


Certified that the inspection of the .. Ideal ... Public ... School,

... I-Block, ... S.D.V. ... Lakhara, Faridabad.

..... School has been carried out on Date. 18.06.2021..... The

Hygienic condition was found
satisfactory/Unsatisfactory

The above Certificate is valid till 31st March 2022 Date




IDEAL PUBLIC SCHOOL


MANAGER



Principal

IDEAL PUBLIC SCHOOL
I-Block, S.D.V. Lakhara
Faridabad (Hr)

For Badami Education Society


Chairman

Signature with Seal:


Civil Surgeon (School Health)
Faridabad